

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PRIVATE SCHOOL  
INSPECTION REPORT



**Facility Information**

**RESULT: Satisfactory**

Permit Number: 16-51-1525012  
Name of Facility: Cornerstone Christian School of Jacksonville  
Address: 9039 Beach Boulevard  
City, Zip: Jacksonville 32216

**Correct By: Next Inspection**  
**Re-Inspection Date: None**

Type: Private School  
Owner: Cornerstone Christian School of Jacksonville  
Person In Charge: Donald Corley Phone: (904) 730-5500  
PIC Email:

**Inspection Information**

Purpose: Reinspection  
Inspection Date: 10/25/2023

Begin Time: 09:15 AM  
End Time: 09:45 AM

**Additional Information**

FEMALES ..... CENSUS ..... 400  
MALES .....

*As per section 120.695, Florida Statutes (FS) this form will serve as a "Notice of Non-Compliance" for any violation noted. Items marked below violate one or more of the requirements of Chapter 6A-2.0040 Florida Administrative Code (FAC). Sanitation Standards in K-12 Private Schools and section 468. Florida Building Code (FBC), Schools, Colleges, and Universities. Violations must be corrected within the time period indicated in the results section above. Continued operation of this facility without making these corrections is a violation of section 6A-2.0040, FAC, and section 468 FBC. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.*

**Violation Markings**

SCHOOL SANITATION	<u>IN</u> 13. Disinfectants	SAFETY
<u>IN</u> 1. School Site	<u>IN</u> 14. Handwash Facilities	<u>IN</u> 25. First Aid Kit
<u>IN</u> 2. Playground	<u>IN</u> 15. Soap Dispensers	DIAPER CHANGING STATION
<u>IN</u> 3. Athletic Equipment	<u>IN</u> 16. Showers	<u>NA</u> 26. Location/Sanitizers
BUILDING	<u>IN</u> 17. Shower Water Temperature	<u>NA</u> 27. Changing Station & Mats
<u>IN</u> 4. Construction	WATER SUPPLY	<u>NA</u> 28. Handsink
<u>OUT</u> 5. Maintenance & Repair	<u>IN</u> 18. Approved Source	<u>NA</u> 29. Garbage Can
<u>IN</u> 6. Lighting Standards	<u>IN</u> 19. Drinking Fountains	ANIMAL HEALTH AND SAFETY
<u>IN</u> 7. Heating, Ventilation, A/C	LIQUID WASTE	<u>NA</u> 30. Vaccination
<u>IN</u> 8. Natural Ventilation	<u>IN</u> 20. Sewage Disposal	<u>NA</u> 31. Animal Maintenance/Aggressive Animals
<u>IN</u> 9. Mechanical Ventilation	<u>IN</u> 21. Solid Waste	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	PEST CONTROL	<u>NA</u> 32. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible	<u>IN</u> 22. Pest Control	<u>NA</u> 33. Other
<u>IN</u> 11. Toilet Floor Drains	<u>IN</u> 23. Brush /Trash	
<u>IN</u> 12. Toilet Facilities	<u>IN</u> 24. Water Collection/Drainage	

*IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation*

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PRIVATE SCHOOL  
INSPECTION REPORT



2 of 2

### General Comments

Correct the listed maintenance and repair violation(s) by time of next routine inspection.

Backstage area has been cleaned and treated by Turner Pest Control.

Overall conditions are satisfactory at this time.

Email Address(es): dcorley@csjax.org

### Violations Comments

Violation #5. Maintenance & Repair

Weather stripping is degraded along the bottom of the outside-exiting doors at the end of the 'U' hall. Doors are located near classroom 'U4' at the end of the sub-section starting near the back entrance to the kitchen.

Degraded weather stripping increases the risk for infestation and diminishes the effectiveness of pest control.

Correct the listed violation(s) by the next routine inspection.

CODE REFERENCE: Maintenance & Repair. 6A-2.0040(3)(b)(c). Buildings shall be kept clean & in good repair, free from hazardous conditions, such as loose or broken floor tiles & boards; loose moldings; loose hanging fixtures, pipes, electric wires; & broken plaster. Furnishings & equipment shall be kept clean & in good repair, free of missing parts & sharp edges.

Inspection Conducted By: John Anderson (82049)  
Inspector Contact Number: Work: (904) 253-1280 ex.  
Print Client Name:  
Date: 10/25/2023

Inspector Signature:

Handwritten signature of John Anderson.

Client Signature:

Handwritten signature of the client.